



City Council Memorandum

To: Mayor Fasbender & City Councilmembers
From: Chris Jenkins, Parks & Recreation Director
Date: February 5, 2024
Item: Budget Amendment

Council Action Requested: Approve requested budget amendment to replace the failed water softener.

Background Information: The water softener that failed is used to condition all of the water at the Hastings Civic Arena, including ice resurfacing water. Conditioned water is essential to prolong plumbing fixture life and maintaining quality ice.

Financial Impact:

This is an unplanned, emergency repair costing \$8,667.64. Staff suggest using Arena Fund Balance to cover this expense.

Advisory Commission Discussion:

N/A

Council Committee Discussion:

N/A

Attachments:

- Robert B. Hill Co. Quote



Quote to: Hastings Civic Arena
Email: cjudge@hastingsmn.gov
Contact: Charlie Judge 651-319-3521
Project: Softener Replacement
From:
Date: 1/24/2024

Scope Replace existing softener **Total** **\$8,667.64**
 (W/O tax)
 (Includes Option)

	Line	Item Number	Description	Quantity	Units	Unit Price	Extended Price
Equip		HICAP-0310-2	24x72 softener vessel with 2" Clack WS2 control valve, 30x50 brine/salt tank.	1			\$5,787.64
Labor			Removal and disposal of existing softener system. Deliver, load, installation and start up of new system.	0			\$2,880.00
Option				0		\$0.00	\$0.00
			Price does not include tax. Includes applicable permit and materials.				
Terms	Due: Net 30						
	Sales tax: Tax will be added where applicable.						
	Freight: FOB Saint Louis Park, MN						
	Availability: Call						
Valid: 30 days							
Quoted by							
Accepted by							

To approve this proposal, please return a signed copy to **Example@hillwater.com** or to the Fax number below

7101 Oxford St St. Louis Park, MN 55426

952-925-1444 FAX 952-925-1471